

Georgia Department of Natural Resources

Environmental Protection Division, Water Protection Branch
4220 International Parkway, Suite 101, Atlanta, Georgia 30354
Permitting, Compliance and Enforcement Program
404/362-2680
FAX: 404/362-2691

August 13, 2002

Brant Keller, PhD
City of Griffin Water & Wastewater Department
Post Office Box T
229 North Expressway
Griffin, Georgia 30223

RE: Expedited Enforcement Compliance Order
No. EPD-PCEP-01-312
Grease Management Plan

Dear Dr. Keller:

On February 26, 2002 the Environmental Protection Division (EPD) and the City of Griffin (City) executed Expedited Enforcement Compliance Order and Settlement Agreement (EECO) No. EPD-PCEP-01-312. Condition C of the EECO requires the City to submit to EPD a grease management plan (Plan) with schedules for implementation.


EPD has received and reviewed the City's May 17, 2002 submittal in accordance with Condition C of the EECO. The City is currently in compliance with Condition C of the EECO. In addition to the incorporation of the Plan into the sewer use ordinance, EPD recommends the City expand the Plan to address:

- Procedures for responding to blockages specifically attributed to grease.
- Development of a Standard Operating Procedure (SOP) to address blockages due to grease where they are occurring at a high frequency, to include increased inspection frequency.

In order to provide a more effective management program, the City should review and revise the draft document in accordance with the above comments. Please submit the revised Plan to EPD upon completion.

If you have any questions, please contact Kisa Tchou at (404) 362-2620. Your cooperation in this matter is appreciated.

Sincerely,



Jeffrey H. Larson, Manager
Permitting, Compliance and Enforcement Program

JHL/kat